

CERTIFICATE OF COMPLIANCE

Certificate Number 20160601-E482027
Report Reference E482027-20160531
Issue Date 2016-JUNE-01

Issued to: SECANTE
Zac Du Fresne-Rue Jacquard
91280 Saint-Pierre Du Perray FRANCE

**This is to certify that
representative samples of**

EMERGENCY LIGHTING AND POWER EQUIPMENT
USL and CNL Model: CETUS series, and G-CETUS W-X-Y-Z
series recessed luminaire Type IC All models are using class 2
LED Driver max 11 Led Drivers used each LE Driver for one
LED Arary max 12 VDC 0.90A
Used one LED Emergency Lighting LED Luminaires
Model GEMINI Ø50 W-X-Y-Z Remote Heads feed by class 2

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 924 - Emergency Lighting and Power Equipment.
UL 1598 - Luminaires.
CSA C.22.2 No. 141-15 - Unit Equipment for Emergency
Lighting.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

